


PLAN

NOTE:

TIE RODS TO BE  
INSTALLED IF HYDRANT  
TEE THRUST BLOCK  
IS BEARING ON  
DISTURBED SOIL.



PROFILE

STRAIGHT LATERAL

APPROVED BY

*JDM*

DATE

4/10/92

**ATTACHED RESIDENTIAL SIDEWALK  
FIRE HYDRANT  
INSTALLATION-MID BLOCK**

DEPARTMENT OF PUBLIC WORKS



DRAWING  
NO.

**R-15**